Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

AWTA PRODUCT TESTING

Client : Gracetech Tex	tiles		Test Number : Issue Date : Print Date : Order Number :	08/07/20 17/07/20 108662	
Sample Description	Woven coated fabric Colour : Lead-black	parent Lead (black)" 9 Polyester, 70% PVC 9 ensity : 430g/m2			
IS 1530.2-1993	Methods for fire tests on buildng materials, components and structures. Part 2: Test for flammability of materials				
	Date Tested			08/07/2015	
	Flammability Index			1	
			Length	Width	
	Spread Factor		0	0	
	Heat Factor		1	1	
aximum height (d)					
	Mean		2.0	2.0	
	Coefficient of Variation		0.0	0.0	%
eat (a)					
	Mean		1.5	1.5	°C.min
	Coefficient of Variation		0.0	0.0	%
	Number of Specimens Tested		6	6	
	Observation	Visible smoke			
	These test results relate only to particular conditions of the test the potential fire hazard of the	, and they are not inter			

©

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Chemical Testing - Mechanical Testing - Performance & Approvals Testing


: Accreditation No. : Accreditation No. : Accreditation No. 983 985

1356

IMITE

lacher

MICHAEL A. JACKSON B.Sc.(Hons)



-

APPROVED SIGNATORY

